

September 23, 2011

Subject: G59/2 Declaration of Conformity

In accordance with Distribution Code, Issue 14, Guidance Note 2 (see note below), the following already G83/1 certified models:

PVI-4.2-OUTD-UK	PVI-5000-OUTD-UK	PVI-6000-OUTD-UK	PVI-10.0-OUTD-UK	PVI-12.5-OUTD-UK
PVI-4.2-OUTD-S-UK	PVI-5000-OUTD-S-UK	PVI-6000-OUTD-S-UK	PVI-10.0-OUTD-S-UK	PVI-12.5-OUTD-S-UK
PVI-4.2-OUTD-UK-W	PVI-5000-OUTD-UK-W	PVI-6000-OUTD-UK-W	PVI-10.0-OUTD-FS-UK	PVI-12.5-OUTD-FS-UK
			PVI-10.0-OUTD-UK-W	PVI-12.5-OUTD-UK-W

will be factory shipped with the upper frequency limit changed from 50.5 Hz to 51.5 Hz. This change will be applied starting from the following serial numbers:

MODEL	SERIAL NUMBER
PVI-4.2-OUTD-UK	616789
PVI-4.2-OUTD-S-UK	
PVI-4.2-OUTD-UK-W	
PVI-5000-OUTD-UK	617451
PVI-5000-OUTD-S-UK	
PVI-5000-OUTD-UK-W	
PVI-6000-OUTD-UK	
PVI-6000-OUTD-S-UK	562918
PVI-6000-OUTD-UK-W	
PVI-10.0-OUTD-UK	
PVI-10.0-OUTD-S-UK	
PVI-10.0-OUTD-FS-UK	
PVI-10.0-OUTD-UK-W	
PVI-12.5-OUTD-UK	
PVI-12.5-OUTD-S-UK	
PVI-12.5-OUTD-FS-UK	
PVI-12.5-OUTD-UK-W	

All products must be installed and commissioned by the 2nd March 2012 to be acceptable under the derogation.

Sincerely,



Tommaso Landi
Business Development Manager
Renewable Energy Products
Power-One Italy S.p.A.

Note:

For more information, please refer to the following link:
<http://www.energynetworks.info/storage/dcode/dcode-pdfs/Distribution%20Code%20for%20GN%20%20only%20hl.pdf>